

### **Non-rising Stem Screw**

The telescoping valve assembly/assemblies shall be manufactured by Latanick Equipment, Inc. Huron, Ohio. The valve shall be sized to fit the riser pipe and penetrate a minimum of 4". The floor stand shall be 3"sch10 stainless steel pipe. The handwheel shall be 14" diameter anodized aluminum and work in conjunction with a stainless steel 1 1/4"-4 double start acme lifting screw, stainless steel ball thrust bearing, delrin gears and delrin nut. The screw and nut shall allow for 1/2" of travel per revolution of the handwheel. The slip pipe shall be stainless steel and have a minimum of 1/8" wall thickness. The companion flange shall be cast iron with a neoprene gasket. The telescoping valve shall be guaranteed against defects in material and/or workmanship for a period of (1) year.